

Office of School Facilities
Rose Diamond, Chief Facilities Officer

SUBJECT: AGREEMENT BETWEEN MIAMI-DADE COUNTY AND THE SCHOOL BOARD OF MIAMI-DADE COUNTY, FLORIDA, FOR THE CONSTRUCTION OF WASTEWATER FACILITIES TO SERVICE THE MARTIN LUTHER KING ELEMENTARY SCHOOL SITE PROJECT NO. A0763D

COMMITTEE: FACILITIES AND CONSTRUCTION REFORM

In order to provide wastewater services to the Martin Luther King Elementary School site and comply with the Consent Agreement between the Department of Environmental Resource Management and the School Board of Miami-Dade County, executed on May 13, 1998, the Board must install and connect an onsite gravity sewer system and other appurtenances to the existing Miami-Dade County (County) infrastructure (see location map).

The 3-acre school site is located at 7124 NW 12 Avenue. A proposed 6-inch sewer lateral shall connect to a County-owned offsite 10-inch gravity sewer main located at NW 71 Street. A utility access port will be installed in order to support the proposed infrastructure. The approximate cost for the installation of these wastewater facilities is \$71,000.

The agreement for the wastewater facilities installation has been reviewed and recommended by the Office of School Facilities and the School Board Attorney's Office. Public utility facilities constructed on Board-owned property will be conveyed, with appropriate easements, to Miami-Dade County for future maintenance and operation.

Fund Source:

Fund: 0376

Object: 5670

Location: 2761


Program: 1316

Func: 7400

RECOMMENDED: That The School Board Of Miami-Dade County, Florida, authorize the Superintendent or his designee to execute an agreement with Miami-Dade County and the execution of relevant conveyance documents for the provision of wastewater services for planned improvements at the Martin Luther King Elementary School site, Project No. A0763D, at an approximate cost not to exceed \$71,000, which is included in the construction contract.

LML

LOCATION MAP



LEGEND



COUNTY-OWNED 10-INCH GRAVITY SEWER MAIN



PROPOSED 6-INCH SEWER LATERAL



PROPOSED UTILITY ACCESS PORT



NORTH